

PLAN


STANDARD TYPICAL RESTRAINED JOINTS

NOTES

1. ALL JOINTS WITHIN DISTANCE "L" SHALL BE RESTRAINED.
2. RESTRAIN JOINTS REQ'D ON FITTING.
3. DISTANCE REQ'D FOR JOINT RESTRAINTS DEPENDS ON FITTING TYPE, SOIL TYPE AND WORKING PRESSURE.
4. DESIGN CRITERIA:
 - a. WORKING PRESSURE: 200 p.s.i.
 - b. SAFETY FACTOR: 1.5.
5. DISTANCE "L" REQUIRED FOR JOINT RESTRAINTS SHALL BE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
6. STAINLESS STEEL BOLTS REQUIRED IN AREAS WITH HIGH WATER TABLE.

REVISION	DATE

S-423



Jones & DeMille Engineering

1535 South 100 West - Richfield, Utah 84701
 (435) 896-8266 Phone
 (435) 896-8268 Fax
 www.jonesanddemille.com

RICHFIELD CITY

WATER - CULINARY

SCALE: NONE

ENG: T.M.J.

PROJ.#: 0501-144

DATE: 01/24/2005

DWG.BY: L.G.

DWG.NAME: water